

# CERTIFICATE OF COMPLIANCE

**Certificate Number** UL-CA-2325017-0  
**Report Reference** E243386-20230920  
**Date** 13-December-2024

**Issued to:** Gefran SPA  
VIA SEBINA 74  
PROVAGLIO D'ISEO, BS 25050  
Italy

**This is to certify that representative samples of** NRNT7 - Switches, Industrial Control Certified for Canada  
See Addendum Page for Product Designation(s).

Have been evaluated by UL in accordance with the Standard(s) indicated on this Certificate.


**Standard(s) for Safety:** CSA C22.2 No. 14:18, 13th Ed., Issue Date: 2018-03,  
Revision Date: 2022-06

**Additional Information:** See the UL Online Certifications Directory at  
<https://iq.ulprospector.com> for additional information

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.

  
Deborah Jennings-Conner, VP Regulatory Services

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



# CERTIFICATE OF COMPLIANCE

**Certificate Number** UL-CA-2325017-0  
**Report Reference** E243386-20230920  
**Date** 13-December-2024

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

<b>Model</b>	<b>Category Description</b>
GRZ-H-3P-2S, followed by - 15, 25, 25I, 30, 30I, 40, 40I, 50, 75, followed by - 48, 60, followed by - D, A, followed by - 0, 1, 2, 3, followed by - 0, FAN62, FAN63, FAN64, followed by - 0, may be followed by alphanumeric digits.	Industrial Control Switches
GRZ-H-3P-3S, followed by - 10, 20, 20I, 25, 25I, 30I, 40, 40I, 65, followed by - 48, 60, followed by - D, A, followed by - 0, 1, 2, 3, followed by - 0, FAN62, FAN63, FAN64, followed by - 0, may be followed by alphanumeric digits.	Industrial Control Switches

*Deborah Jennings-Conner*

Deborah Jennings-Conner, VP Regulatory Services

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



# CERTIFICATE OF COMPLIANCE

**Certificate Number**    UL-CA-2325017-0  
**Report Reference**     E243386-20230920  
**Date**                      13-December-2024

**SHORT CIRCUIT RATINGS:**

The following models are suitable for use on a circuit capable of delivery not more than 100,000 rms symmetrical amperes at maximum 600 Vac 3PH, when protected by UL Listed (JDDZ) fuses with size and class as specified in the table below:

SCR's Switch Model Nos. Nomenclature		Fuse Class	Fuse Current Maximum Size (A)	Minimum enclosure size width x height x depth (mm)
Item: I + II	Item: III			
GRZ-H-3P-2S	15	J	40	79 x 165 x 161
		CC	30	79 x 165 x 161
	25	J	40	--
		CC	30	--
	25I	J	80	--
	30	J	40	--
		CC	30	--
	30I	J	80	--
	40	J	40	--
	40I	J	80	--
50	J	80	--	
75	J	80	--	
GRZ-H-3P-3S	10	J	40	79 x 165 x 161
		CC	30	79 x 165 x 161
	20	J	40	--
		CC	30	--
	20I	J	80	--
	25	J	40	--
		CC	30	--
	25I	J	80	--
	30I	J	80	--
	40	J	40	--
40I	J	80	--	
65	J	80	--	

  
 Deborah Jennings-Conner, VP Regulatory Services  
 UL LLC



Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

# CERTIFICATE OF COMPLIANCE

**Certificate Number** UL-US-2329182-0  
**Report Reference** E243386-20230920  
**Date** 13-December-2024

**Issued to:** Gefran SPA  
VIA SEBINA 74  
PROVAGLIO D'ISEO, BS 25050  
Italy

**This is to certify that representative samples of** NRNT - Switches, Industrial Control  
See Addendum Page for Product Designation(s).

Have been evaluated by UL in accordance with the Standard(s) indicated on this Certificate.

**Standard(s) for Safety:** UL 508, 18th Ed., Issue Date: 2018-03-30, Revision Date: 2021-07-08

**Additional Information:** See the UL Online Certifications Directory at <https://iq.ulprospector.com> for additional information

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.

*Deborah Jennings-Conner*

Deborah Jennings-Conner, VP Regulatory Services

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



# CERTIFICATE OF COMPLIANCE

**Certificate Number** UL-US-2329182-0  
**Report Reference** E243386-20230920  
**Date** 13-December-2024

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

<b>Model</b>	<b>Category Description</b>
GRZ-H-3P-2S, followed by - 15, 25, 25I, 30, 30I, 40, 40I, 50, 75, followed by - 48, 60, followed by - D, A, followed by - 0, 1, 2, 3, followed by - 0, FAN62, FAN63, FAN64, followed by - 0, may be followed by alphanumeric digits.	Industrial Control Switches
GRZ-H-3P-3S, followed by - 10, 20, 20I, 25, 25I, 30I, 40, 40I, 65, followed by - 48, 60, followed by - D, A, followed by - 0, 1, 2, 3, followed by - 0, FAN62, FAN63, FAN64, followed by - 0, may be followed by alphanumeric digits.	Industrial Control Switches

*Deborah Jennings-Conner*

Deborah Jennings-Conner, VP Regulatory Services

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



# CERTIFICATE OF COMPLIANCE

Certificate Number UL-US-2329182-0  
 Report Reference E243386-20230920  
 Date 13-December-2024

## SHORT CIRCUIT RATINGS:

The following models are suitable for use on a circuit capable of delivery not more than 100,000 rms symmetrical amperes at maximum 600 Vac 3PH, when protected by UL Listed (JDDZ) fuses with size and class as specified in the table below:

SCR's Switch Model Nos. Nomenclature		Fuse Class	Fuse Current Maximum Size (A)	Minimum enclosure size width x height x depth (mm)
Item: I + II	Item: III			
GRZ-H-3P-2S	15	J	40	79 x 165 x 161
		CC	30	79 x 165 x 161
	25	J	40	--
		CC	30	--
	25I	J	80	--
	30	J	40	--
		CC	30	--
	30I	J	80	--
	40	J	40	--
	40I	J	80	--
	50	J	80	--
75	J	80	--	
GRZ-H-3P-3S	10	J	40	79 x 165 x 161
		CC	30	79 x 165 x 161
	20	J	40	--
		CC	30	--
	20I	J	80	--
	25	J	40	--
		CC	30	--
	25I	J	80	--
	30I	J	80	--
	40	J	40	--
	40I	J	80	--
65	J	80	--	

*Deborah Jennings-Conner*  
 Deborah Jennings-Conner, VP Regulatory Services



UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>