

# TYPE TEST CERTIFICATE

**Equipment:** Oil temperature indicator without contact (dial thermometer)  
Type 608005

The above mentioned equipment has been successfully type tested to the requirements of the standard detailed hereon:

- Tests:**
1. Accuracy class 1,5 similar to standard DIN EN 13190
  2. IP55 protection as per standard DIN EN 60529
  3. Plastic parts – Ageing, chemical and environmental resistance as per standard DIN EN ISO 4892-2A
  4. functional test after temperature ageing in a climate chamber between -50°C and +80°C as per JUMO factory standard
  5. salt mist test as per standard DIN EN 60068-2-11

Fulda, 2016-04-29

**JUMO GmbH & Co. KG**  
Moritz-Juchheim-Straße 1 36039 Fulda, Germany  
Tel.: +49 661 6003-0 Fax: +49 661 6003-500  
mail@jumo.net www.jumo.net

Christoph Trott  
Head of Productmanagement Automation