


TYPE TEST CERTIFICATE

Equipment: Oil temperature indicator with contact (contact dial thermometer)
Type 608523

The above mentioned equipment has been successfully type tested to the requirements of the standard detailed hereon:

- Tests:**
1. Accuracy class 1,5 similar to standard DIN EN 13190
 2. IP65 protection as per standard DIN EN 60529
 3. Plastic parts – Ageing, chemical and environmental resistance as per standard DIN EN ISO 4892-2A
 4. functional test after temperature ageing in a climate chamber between -50°C and +80°C as per JUMO factory standard
 5. salt mist test as per standard DIN EN 60068-2-11
 6. Safety requirements for electrical equipment for measurement, control and laboratory use as per standard DIN EN 61010-1
 7. Contact rating 230V / 10A (with extra code 650 only)

Fulda, 2016-04-29


JUMO GmbH & Co. KG
Moritz-Juchheim-Straße 1 36039 Fulda, Germany
Tel.: +49 661 6003-0 Fax: +49 661 6003-500
mail@jumo.net www.jumo.net

Christoph Trott
Head of Productmanagement Automation