



IECEx Certificate of Conformity

INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification System for Explosive Atmospheres

for rules and details of the IECEx Scheme visit www.iecex.com

Certificate No.: **IECEx IBE 20.0029X** Page 1 of 3 [Certificate history:](#)

Status: **Current** Issue No: 0

Date of Issue: 2020-10-21

Applicant: **JUMO GmbH & Co KG**
Moritz-Juchheim-Straße 1, 36039 Fulda, Germany
Germany

Equipment: **Ex-i isolated switch amplifier type 707540/38**

Optional accessory:

Type of Protection: **intrinsic safety "i" in combination with increased safety "ec" and type of protection "n", sealed device**

Marking: [Ex ia Ma] I
[Ex ia Ga] IIC
[Ex ia Da] IIIC
Ex ec nC [ia Ga] IIC T4 Gc
-40 °C ≤ T_{amb} ≤ +60 °C

Approved for issue on behalf of the IECEx
Certification Body:

Alexander Henker

Position:

Deputy Head of department Certification Body

Signature:
(for printed version)

Date:

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting www.iecex.com or use of this QR Code.



Certificate issued by:

IBExU Institut für Sicherheitstechnik GmbH
Fuchsmühlenweg 7
09599 Freiberg
Germany



IECEX Certificate of Conformity

Certificate No.: **IECEX IBE 20.0029X**

Page 2 of 3

Date of issue: 2020-10-21

Issue No: 0

Manufacturer: **JUMO GmbH & Co KG**
Moritz-Juchheim-Straße 1, 36039 Fulda, Germany
Germany

Additional
manufacturing
locations:

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended

STANDARDS :

The equipment and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards

IEC 60079-0:2017 Explosive atmospheres - Part 0: Equipment - General requirements
Edition:7.0

IEC 60079-11:2011 Explosive atmospheres - Part 11: Equipment protection by intrinsic safety "i"
Edition:6.0

IEC 60079-15:2017 Explosive atmospheres - Part 15: Equipment protection by type of protection "n"
Edition:5.0

IEC 60079-7:2017 Explosive atmospheres - Part 7: Equipment protection by increased safety "e"
Edition:5.1

This Certificate **does not** indicate compliance with safety and performance requirements other than those expressly included in the Standards listed above.

TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in:

Test Report:

[DE/IBE/ExTR20.0036/00](#)

Quality Assessment Report:

[DE/TUN/QAR13.0005/07](#)



IECEx Certificate of Conformity

Certificate No.: **IECEx IBE 20.0029X**

Page 3 of 3

Date of issue: 2020-10-21

Issue No: 0

EQUIPMENT:

Equipment and systems covered by this Certificate are as follows:

The Ex-i isolated switch amplifiers 707540/38 are used for the intrinsically safe and galvanically iso-lated operation of proximity switches with NAMUR behaviour or potential-free switches and resistance-connected switches. They are equipped with a wide voltage range supply. The equipment is provided for installation in zone 2 or in the safe area as associated apparatus. The intrinsically safe signal circuits may be routed into areas that require EPL Ma, Ga (Zone 0) or Da (Zone 20).

The voltage difference between input and output circuit or supply can be up to 375 V peak. The modules are equipped with a circuit for the detection of line faults.

The technical data are mentioned in the Annex.

SPECIFIC CONDITIONS OF USE: YES as shown below:

- The Ex-i isolated switch amplifiers have to be installed in a certified housing fulfilling the requirements of EN 60079-7 or another recognized type of protection. The housing has to maintain a degree of protection of at least IP54 according to IEC 60529 for operation in zone 2.
- Connecting and disconnecting of non-intrinsically safe circuits are not allowed in energized state.
- The DIP Switches may only be used if no explosive atmosphere is present.

Annex:

[Annex_IBE20.0029X_00.pdf](#)



IECEX Certificate of Conformity - Annex



Certificate No: IECEx IBE 20.0029X

Issue No: 0

Date of Issue: 2020-10-21

Page 1 of 1

Technical data:

Environmental data	
Ambient temperature range	-40 °C up to +60 °C
Degree of protection of the enclosure	≥ IP20

Electrical data			
1.	Power Supply (1.1 and 1.2)		
	rated voltage range	U_N	24 ... 230 V DC or AC
	supply current	I_N	< 42 mA (24 V DC); max. < 80 mA (20 V AC)
	power consumption	P_{in}	< 1.1 W
	maximum r.m.s. or d.c. voltage	U_m	253 V
	galvanically separated up to a peak voltage	U_p	375 V
2.	Intrinsically safe sensor circuit (4.1 and 4.3/5.1 and 5.3)		
	maximum output voltage	U_o	9.56 V
	maximum output current	I_o	10.3 mA
	maximum output power	P_o	25 mW
	characteristic		linear (928 Ω)
	internal capacitance, inductance	$C_i; L_i$	negligible
3.	Relay output (2.1 ... 2.3 / 3.1 ... 3.3)		
	maximum switching voltage	U_s	250 V AC (2 A) / 120 V DC (0.2 A) / 30 V DC (2 A)
	maximum switching power	P_s	500 VA

For circuits including inductances and capacitances the following has to be observed:

The values for L_o and C_o , mentioned in this certificate are allowed for:

- distributed inductances and capacitances, e.g. as in a cable or
- if the total L_i of the external circuit (excluding the cable) is < 1 % of the L_o value or
- if the total C_i of the external circuit (excluding the cable) is < 1 % of the C_o value.

	Ex ia IIC	Ex ia IIB/IIIC	Ex ia IIA, Ex ia I
C_o	3.6 μF	26 μF	210 μF
L_o	300 mH	1000 mH	1000 mH

The values of L_o and C_o , mentioned in this certificate shall be reduced to 50 % or taken from the following table if both of the following conditions are met:

- the total L_i of the external circuit (excluding the cable) is ≥ 1 % of the L_o value and
- the total C_i of the external circuit (excluding the cable) is ≥ 1 % of the C_o value.

	Ex ia IIC					Ex ia I, Ex ia IIB/IIA, Ex ia			
C_o	510 nF	580 nF	600 nF	600 nF	600 nF	1 μF	1 μF	1 μF	1 μF
L_o	100 mH	50 mH	5 mH	1 mH	10 μH	100 mH	5 mH	1 mH	10 μH

The reduced capacitance of the external circuit (including cable) shall not be greater than 1 μF for Groups I, IIA and IIB and 600 nF for Group IIC.