


CERTIFICATE

Certificate holder	JUMO GmbH & Co. KG Moritz-Juchheim-Str. 1 36039 Fulda GERMANY
Product	Temperature control and limiting devices for heat generating systems
Type, Model	ATH-70, ATH-SE-70, ATH-SW-70
Testing basis	DIN EN 14597:2015-02 Certification scheme Temperature control and limiting devices for heat generating systems (2009-01)
Mark of conformity	
Registration No.	STB895
Valid until	2027-12-31
Right of use	This certificate entitles the holder to use the mark of conformity shown above in conjunction with the specified registration number. See annex for further information.

ANNEX

Certificate	STB895 dated 2022-12-21
Technical Data	<p>Tension meter movement with hydro-inflation or gas filling, devise with extended security</p> <p>See technical data sheet to the above mentioned registration number at www.dincertco.tuv.com</p> <p>the Temperature control and limiting devices is suitable for</p> <ul style="list-style-type: none">- safety temperature limiter (STB) with the modes of action 2B, 2F, 2K, 2L, 2N, 2P, 2V
Testing laboratory/ Inspection body	<p>TÜV SÜD Industrie Service GmbH Prüflabor für Kälte-, Klima- u. Wärmetechnik Ridlerstr. 65 80339 München GERMANY</p>
Test report(s)	<p>C-T 1356-01/12 dated 2012-11-23 C-T-1356-003/17 dated 2017-11-09 C-T 1356-04/22 dated 2022-12-12</p>
Remark(s)	<p>Based on the examination</p> <p>DIN EN 60730-2-9:2011-07 DIN EN 60730-1:2012-10 DIN EN 60730-1:2017-05 DIN EN 60335-1:2012-10, paragraph 30</p>

