



UK Declaration of Conformity

Document No. UK 24
Manufacturer JUMO GmbH & Co. KG
Address Moritz-Juchheim-Straße 1, 36039 Fulda, Germany

Product

| Name | Type | Data sheet no. |
|--------------------|--------|----------------|
| JUMO AQUIS touch S | 202581 | 202581 |

Product description

Modular multichannel measuring device (liquid analysis).

We hereby declare in sole responsibility that the designated product fulfills the requirements of the statutory instruments.

1. Statutory instrument

| | |
|--|--|
| Name | Electromagnetic Compatibility Regulations 2016 |
| Conformity assessment procedure | Mod. A |
| Date of first application of the UKCA mark to the product | 2021 |

Standards/Specifications applied

| Reference | Edition | Comment |
|------------|---------|---------|
| EN 61326-1 | 2013 | |

Valid for Type

202581/...



More than **sensors + automation**

2. Statutory instrument

Name Electrical Equipment (Safety) Regulations 2016

Conformity assessment procedure Mod. A

Date of first application of the UKCA mark to the product 2021

Standards/Specifications applied

| Reference | Edition | Comment |
|------------|----------------------|---------|
| EN 61010-1 | 2010+A1:2019/AC:2019 | |

Valid for Type

202581/...

3. Statutory instrument

Name The Restriction of the Use of Certain Hazardous Substances in Electrical and Electronic Equipment Regulations 2012

Conformity assessment procedure Mod. A

Date of first application of the UKCA mark to the product 2021

Standards/Specifications applied

| Reference | Edition | Comment |
|---|---------|---------|
| [VDK] Umweltrelevante Aspekte V1 bei der Produktentwicklung und -gestaltung | | |

Valid for Type

202581/...

JUMO GmbH & Co. KG

Moritz-Juchheim-Straße 1
36039 Fulda, Germany

Tel.: +49 661 6003-0
Fax: +49 661 6003-500

E-Mail: mail@jumo.net
Internet: www.jumo.net



More than **sensors + automation**

Issued by

Place, date

Legally binding signatures

JUMO GmbH & Co. KG

Fulda, 2021-11-12

Director of Global Sales
Markus Belmer

A handwritten signature in blue ink, appearing to read "M. Belmer".

Head of Quality Department
Harald Gienger

A handwritten signature in blue ink, appearing to read "Harald Gienger".