

FOUNDATION™

DEVICE REGISTRATION

Manufacturer: ABB Automation Products, GmbH

Model: TTX 300 series
Type: Temperature Transmitter

Device ITK Version: 5.2.0
Device Test Campaign: IT066100

Test Report: FF-527-(66100)

Stack Test Campaign: CT0120FF
Physical Layer Test Report: PT-317
Physical Layer Profiles: 111, 113, 121, 123, 511


Manufacturer ID: 0x000320
Device Type: 0x001F
Device Revision: 0x01

	Filename	CRC	ITK Version
Device Description:	0101.ffo	A436A464	5.2.0
	0101.sym	2C62B635	5.2.0
	0101.ff5	E8DB9AB	5.2.0
	0101.sy5	2C62B635	5.2.0
Capability File:	010101.cff	F9CB6B0	5.2.0

Tested Features: Resource Block
Alarms and Events
Function Block Linking
Trending
Analog Input Function Blocks
Analog Output Function Block
Discrete Input Function Blocks
PID Control Function Block

29 January 2010

Registration Date



Richard J. Timoney
President and CEO