



# 中国国家强制性产品认证证书



证书编号: 2020322307002100

认证委托人名称: 上海ABB工程有限公司

认证委托人地址: 上海市浦东新区康新公路4528号

生产者名称: ABB AG

生产者地址: Schillerstraße 72, 32425 Minden, Germany

生产企业名称: ABB AG

生产企业地址: Schillerstraße 72, 32425 Minden, Germany

产品名称: 数字阀门定位器 TZIDC200

系列、规格、型号: TZIDC200 V18348, TZIDC210 V18349, TZIDC220 V18350

标准: GB/T 3836.1-2021、GB/T 3836.2-2021

认证模式: 型式试验+初始工厂检查+获证后监督

上述产品符合CNCA-C23-01:2024《强制性产品认证实施规则 防爆电气》的要求, 特发此证。

产品相关信息详见附件。

发证日期: 2025年09月10日 有效期至: 2030年09月09日

首次发证日期: 2020年09月26日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询

(注意: 图片中的数据与真实证书一致, 但显示形式不完全相同)



批准: \_\_\_\_\_



上海仪器仪表自控系统检验测试所有限公司



# 中国国家强制性产品认证证书

证书编号：2020322307002100

证书附页：第1页 共2页

产品名称：

数字阀门定位器 TZIDC200

型号规格：

TZIDC200 V18348 \*\*/ \*/a/\*\*/\*\*/\*\*/\*\*/\*\*/\*\*/\*\*/\*\*/\*\*/\*\*/\*\*/\*\*/\*\*/\*\*/\*\*/\*\*/

a stands for Explosion Protection/Approvals which can be:

1 for ATEX Ex d II C T4/T5/T6 Gb

6 for IECEx Ex db II C T4/T5/T6 Gb

X for NEPSI Ex db IIC T4/T5/T6 Gb

b stands for Certifications which can be:

CCC for CCC Approval for China, NEPSI Ex db IIC T4/T5/T6 Gb, When the CCC- order code is combined with other Explosion Protection Approvals, eg. TZIDC200 V18348 \*\*/ \*/1/\*\*/\*\*/\*\*/\*\*/\*\*/\*\*/\*\*/\*\*/\*\*/\*\*/\*\*/\*\*/\*\*/\*\*/\*\*/\*\*/CCC/, it meets both Explosion Protection Approvals.

\*...is not related to explosion-proof performance

TZIDC210 V18349 \*\*/ \*/a/\*\*/\*\*/\*\*/\*\*/\*\*/\*\*/\*\*/\*\*/\*\*/\*\*/\*\*/\*\*/\*\*/\*\*/\*\*/

a stands for Explosion Protection/Approvals which can be:

1 for ATEX Ex d II C T4/T5/T6 Gb

6 for IECEx db IIC T4/T5/T6 Gb;

X for NEPSI Ex db IIC T4/T5/T6 Gb

b stands for Certifications which can be:

CCC for CCC Approval for China, NEPSI Ex db IIC T4/T5/T6 Gb, When the CCC- order code is combined with other Explosion Protection Approvals, eg. TZIDC210 V18349 \*\*/ \*/1/\*\*/\*\*/\*\*/\*\*/\*\*/\*\*/\*\*/\*\*/\*\*/\*\*/\*\*/\*\*/\*\*/\*\*/\*\*/CCC/, it meets both Explosion Protection Approvals.

\*...is not related to explosion-proof performance

TZIDC220 V18350 \*\*/ \*/a/\*\*/\*\*/\*\*/\*\*/\*\*/\*\*/\*\*/\*\*/\*\*/\*\*/\*\*/\*\*/\*\*/\*\*/\*\*/

a stands for Explosion Protection/Approvals which can be:

1 for ATEX Ex d II C T4/T5/T6 Gb

6 for IECEx db IIC T4/T5/T6 Gb;

本页为证书附页，应与证书主页同时使用。



SITIIAS  
Worldwide Access

批准：

上海仪器仪表自控系统检验测试所有限公司

