



EXPLOSION PROTECTION

CERTIFICATE OF CONFORMITY

Cert No. GYJ24.1112X

Manufacturer	ABB AG (Address: Schillerstraße 72, 32425 Minden, Germany)
Product	Digital Positioner
Model	TZIDC HW-Rev.: 5.01 V18345 / TZIDC-200 HW-Rev.: 5.01 V18348 Series
Ex marking	Ex ia IIC T6/T4...T1 Gb, Ex ib IIC T6/T4...T1 Gb
Product standard	/
Drawing number	901288_TZIDC_General_Construction_Setup_Rev_5

The product was found to comply with the following standard(s):

GB/T 3836.1-2021, GB/T 3836.4-2021

Valid until: 2029.04.21

Remarks

1. Conditions for safe use are specified in the attachment to this certificate.
2. Symbol "X" placed after the certification number denotes specific conditions of use, which are specified in the attachment to this certificate.
3. Safe parameters specified in the attachment to this certificate.

Approval

Shanghai Inspection and Testing Institute of
Instruments and Automation Systems Co., Ltd.
National Supervision and Inspection Center for
Explosion Protection and Safety of Instrumentation
Date of issue 2024.04.22

This Certificate is valid for products compatible with the documents and samples approved by NEPSI.