	<h1>Certificate</h1>
Railway application According to EN 50155:2021	
Manufacturer Address	JUMO GmbH & Co. KG Moritz-Juchheim-Straße 1, 36039 Fulda, Germany
Product description Model and/or type	Humidity and temperature transmitter (duct version) 907043 ¹ + extra code 950 railway application

Classification			
Nominal voltage:	DC 24 V	Fast temperature change class:	H1
Power supply interruption class:	S2	PCB coating class:	PC1
Power supply switching class:	C1	Mechanical category/class:	1/B
Operation temperature class:	OT2/OT4 ²	Lifespan:	L2
Switching temperature class:	ST0	Altitude class:	A1

Tests performed			
	Test and requirements	Standard	Result
1	Visual inspection	EN 50155:2021	Passed
2	Performance Test	EN 50155:2021	Passed
3	DC power supply test $0.6 * U_{Nenn}$ $1.4 * U_{Nenn}$	EN 50155:2021 EN 61000-4-29:2000	Passed
4	Low temperature test $-40\text{ °C, min. } 2\text{ h}$	EN 50155:2021 EN 60068-2-1:2007	Passed
5	Dry heat test $55\text{ °C, } 8\text{ h}$ $70\text{ °C, } 8\text{ h}$	EN 50155:2021 EN 60068-2-2:2007	Passed
6	Low temperature storage test	Test on inquiry	---
7	Insulation test	Not applicable	---
8	Cyclic damp heat test	Test on inquiry	---
9	Electromagnetic compatibility test (EMC)	EN 50121-3-2:2016	Passed
	EMC: Emission	EN 50121-3-2:2016 EN 61000-6-4:2007+A1:2011	Passed
	EMC: Immunity ESD $6\text{ kV Contact; } 8\text{ kV Air}$	EN 50121-3-2:2016 EN 61000-4-2:2009	Passed

¹ Humidity and temperature only



² OT4 for device without display



**MORE THAN SENSORS
AND AUTOMATION**

#	Test and requirements	Standard	Result
	EMC: Immunity RF-Field 80-1000 MHz, 20 V/m, 1400-2000 MHz, 10 V/m 2000-2700 MHz, 5 V/m 5100-6000 MHz, 3 V/m	EN 50121-3-2:2016 EN 61000-4-3:2006+A1:2008+A2:2010	Passed
	EMC: Immunity Burst 2 kV, 5 kHz	EN 50121-3-2:2016 EN 61000-4-4:2012	Passed
	EMC: Immunity Surge 1 kV Line-Line 2 kV Line-Earth	EN 50121-3-2:2016 EN 61000-4-5:2014	Passed
	EMC: Immunity Conducted-RF 0.15-80 MHz, 10 V	EN 50121-3-2:2016 EN 61000-4-6:2014	Passed
10	Shock and vibration test	EN 61373:2010	Passed
	Broadband random noise 1.01 m/s ² , 5-150 Hz, ASD 0.03 (m/s ²)/Hz, 10 min	EN 61373:2010 EN 60068-2-64:2008	Passed
	Simulated Lifetime 5,72 m/s ² , 5-150 Hz, 5 h	EN 61373:2010 EN 60068-2-64:2008	Passed
	Shock 50 m/s ² , 24 ms, 3 Shocks	EN 61373:2010 EN 60068-2-27:2009	Passed
11	Enclosure protection test (IP-Code) IP65	EN 60529:1991+A2:2013/AC:2019	Passed
12	Stress screening test	Test on inquiry	---
13	Rapid temperature variation test	Test on inquiry	---
14	Salt mist test	Test on inquiry	---
15	Fire behaviour of materials HL1 to HL3, burning mass ≤ 100 g / ≤ 400 g	EN 45545-1:2013 EN 45545-2:2020	Passed

Test laboratories used:	for test no.:
Internal laboratory JUMO	11
Internal accredited laboratory JUMO (IEC 17025)	1-10
External accredited laboratory (IEC 17025)	15

JUMO GmbH & Co. KG, Moritz-Juchheim-Strasse 1, 36039 Fulda, Germany	
Date	Signature
Fulda, April 1, 2025	<div style="display: flex; justify-content: space-around;"> <div style="text-align: center;">  o.b.o. Dr.-Ing Jan-Florian Höfinghoff Test laboratory </div> <div style="text-align: center;">  o.b.o. Justin Heinrich Product management </div> </div>